

Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No.

Dated:

It is certified that an inspection team headed by Ravi Kumar Nishwakar ma J.E (T.E)

(Name of Officers with designation) from N.P.P. Bhadohi PHED

inspected the "Sunbeam School, Rajpura Crossing, Aurai Road, Bhadohi, Uttar Pradesh Pin:221401"

on 23/04/24 (date of inspection) and on the basis of Water Test Report (Attached) bearing no TEST REPORT/EXE. ENQ. CON. DIVI/chemical Test/09/2024-27
and Microbial Test/10/2024-25 dated 29/4/24 of District Water Analysis Labrotary (U.P.) (PH

ED Lab) certified that the Sunbeam School has safe drinking water facilities for the students and members

of staff of the institution. School also maintains the hygienic sanitation condition in the school building &

the campus as per norms prescribed by the Central/ State/ U.T. Govt.

This certificate is valid till 22/4/2025

Signature with Seal: [Signature] 29/4/24

Name : Ravi Kumar अवर. अभियन्ता (जल)

Designation : J.E. (T.E) नगर प्रालिक परिषद
भदोही

Name & Address of the Office / Department: Nagar Palika

Parishad Bhadohi

To,
Sunbeam School
Rajpura Crossing
Aurai Road

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies



[Signature]
Principal
SUNBEAM SCHOOL
Bhadohi



Test Report

District water Analysis Laboratory UP Jal Nigam(Rural)

MIG II 11&12 Jamunipur Colony

Sant Ravidas Nagar (Bhadohi)-221409

Report No.	Test Report / Exe .Eng. Con .Divi. / Chemical Test /09 /2024-27	Issue Date	29/04/2024	Page No	1 of 2
------------	---	------------	------------	---------	--------

Customer Details

Office Name and Address	Sunbeam School Rajpura Crossing , Aurai Distt. Sant Ravidas Nagar Bhadohi (221401)
Ref Letter No & Date	NA

Basic details of sample

District	Sant Ravidas Nagar	Block	Bhadohi
Nagar Panchyat	Bhadohi	Village	-
Habitation	-	Location	Rajpura
Water Source	Drinking Water	Sample Code	B/24/04/933
Quantity of Sample	1.0 Ltr	Date Of S.C.	24/04/2024
Receiving Date	24/04/2024	S. Collector	Party
Sample Depositor	Party	Sampling Method Used	IS:17614:P-1:021
Analysis Start Date	26/04/2024	Analysis Completion Date	27/04/2024

Environmental Condition

Temperature	25 ± 3°C	Humidity	50 ± 15%
-------------	----------	----------	----------

Technical Data of Analysis

S.No	Analyzed Parameters	Unit of Measurement	Observed value	Limits of IS: 10500-2012		Reference Method of Analysis
				Desirable Limit (Max)	Permissible Limit in the Absence of Alternate Source (Max)	
1.	pH	—	6.85	6.5-8.5	No relaxation	IS : 3025 (Part 11) - 2022
2.	Colour	Hazen	<5	5	15	APHA 24th Edition 2120 Colour Method B Platinum Cobalt Visual Comparison-2023
3.	Odour	—	Agreeable	Agreeable	Agreeable	IS 3025 (Part 5) : 2022
4.	Taste	—	Agreeable	Agreeable	Agreeable	IS : 3025 (Part 8) - 2023
5.	Turbidity	NTU	0.76	01	05	IS : 3025 (Part 10) - 2023
6.	Total Dissolve Solids	mg/l	78.0	500	2000	IS : 3025 (Part 16) - 2023
7.	Total Alkalinity (as CaCO ₃)	mg/l	80.0	200	600	IS 3025 (Part 23) : 2023
8.	Total Hardness(as CaCO ₃)	mg/l	80.0	200	600	IS 3025 (Part 21) : 2019
9.	Calcium as Ca	mg/l	8.0	75	200	IS 3025 (Part 40) : 2023
10.	Magnesium as Mg	mg/l	4.88	30	100	IS 3025 (Part 46) : 2023
11.	Sulphate (as SO ₄)	mg/l	7.45	200	400	APHA 24th Edition – 4500-SO ₄ Method E (Turbidity Method ,2023)
12.	Nitrate (as NO ₃)	mg/l	2.37	45	No relaxation	APHA 24th Edition – 4500-NO ₃ Method B (UV Screening Method ,2023)
13.	Iron (as Fe)	mg/l	BDL	1.0	No relaxation	APHA 24th Edition – 3500- Fe Method B (Phenanthroline ,2023)

Principal
SUNBEAM SCHOOL
Bhadohi



14.	Fluoride	mg/l	BDL	1.0	1.50	APHA 24th Edition -4500-F Method C (Electrode Method) 2023
15.	Chloride (as Cl)	(mg/l)	9.99	250	1000	IS 3025 (Part 32) : 2023

*BDL-Below Detection Limit.

- Note- 1. This certificate refers only to the particular samples submitted for testing.
 2. This certificate shall not be reproduced ,except in full, unless written permission for the publication of an approved abstract .
 3. The test results reported in this certificate are valid at the time of and under the started conditions of measurements.
 4. Sample will be stored up to 7 days (in case of non perishable items only) from the date of issue of tests reports .

Froz Ali
 Prepared by:
 Froz Ali
 (Deputy Quality manager)

Mahendra Pal
 Authorized signatory
 Mahendra Pal
 (Technical manager)



Laboratory contact details :- Name- Mahendra Pal
 Mo. No. 9919087307
 Email ID:-mahendrapal4491@gmail.com

*** END OF REPORT***

Principal
 Principal
 SUNBEAM SCHOOL
 BHADRA





DISTRICT WATER ANALYSIS LABORATORY, UTTAR PRADESH

JAL NIGAM,

SANT RAVIDAS NAGAR (BHADOHI)

Analysis Report

Water Analysis Laboratory, U.P. Jal Nigam

Report No.	Test Report / Exe .Eng. Con .Divi. / Microbial Test /10/2024-25	Issue Date	29/04/2024	Page No	01		
Customer Details							
Office Name and Address	Sunbeam School Rajpura Crossing , Aurai Distt. Sant Ravidas Nagar Bhadohi (221401)						
Ref Letter No & Date	NA						
Basic details of sample							
District	Sant Ravidas Nagar Bhadohi	Block	Bhadohi				
Nagar Panchyat	Bhadohi	Village	-				
Habitation	-	Location	Rajpura				
Water Source	Drinking Water	Sample Code	B/24/04/933				
Quality of Sample	1.0 Letter	Date Of S.C.	24/04/2024				
Receiving Date	24/04/2024	S. Collector	Party				
Sample Depositor	Party	Sampling Method Used	IS:1622-2003				
Analysis Start Date	26/04/2024	Analysis Completion Date	27/04/2024				
Environmental Condition							
Temperature	25 ± 3°C	Humidity	50 ± 15%				
Technical Data of Analysis							
S. No	Parameters	Observed value	Unit	Limits of IS: 10500-2012			
				Desirable Limit (Max)	Permissible Limit in the Absence of Alternate Source (Max)	Reference Method of Analysis	
1.	Total coli form	E. coli	NIL	CFU/100ML	NIL	NIL	IS 15185:2016
		T. Coliform	NIL				

Manish Kumar Yadav
Prepared by:
Manish Kumar Yadav

Mahendra Pal
Authorized signatory
Mahendra Pal

Laboratory contact details :- Name- Mahendra Pal
Mo. No. 9919087307
Email ID:-mahendrapal4491@gmail.com



*** END OF REPORT***

10/4/24
Principal
SUNBEAM SCHOOL
BHADOHI

Mahendra Pal
SUNBEAM SCHOOL
BHADOHI